

Product Data Sheet

GW90923


90 ReStart Range




Description Automatic reclosing device
Code ReStart Autotest PRO 4P
Rated voltage AC 400 V
Rated current 63 A
No. modules 7
Standard EN 50557, EN 61008-1
Rated frequency (Hz) 50Hz
Distribution system TT - TN-S

Rated non-operating resistance between live parts and earth (Rdo) $$8 k\Omega$$		Insulation voltage	500 V	
Rated operating resistance between live parts and earth (Rd) 16 kΩ		Rated impulse withstand voltage	4 kV	
Maximum operating frequency		30 oper./h	Overvoltage category	III
Mechanical endurance		4000	Dielectric strength test voltage between pole and earth	2500 Vac for 1 minute
Type of residual current protection		A[IR]	Rated residual operating current	30 mA
Operating temperature		-25 +60 °C	Stocking temperature	-40 +70 °C
Type of contacts	Photomo	os (potential free)	Voltage operating	5-230 V ac/dc
Current operating	0.6mA (min)-100	0mA cos=1 (max)	Operating frequency	50 Hz
Use category		AC12	Operating modes	NO/NC/NC + pulse
Rated tightening torque		0,4 Nm	Terminal section	≤ 2,5 mm²
Automatic reclosure for untimely tripping Yes		Earth failure test	Yes	
Continuous system monitoring Yes		Autotest (automatic RCCB protection test)	Yes	
Complete with	One device among: GW90954 Wi-Fi Mo	odule - GW90992	Number of poles	4P
	RS	485 BUS Module		
Electrocod 1414		Compatibility with WiFi interface	Yes	

DIMENSIONAL





STANDARDS/APPROVALS





GEWISS S.p.A. Via A. Volta, 1 24069 Cenate Sotto - Bergamo - Italy tel. +39 035 94 61 11 fax +39 035 94 69 09

www.gewiss.com sat@gewiss.com Last update 12/04/2021 Data, measures, designs and pictures are shown only as informative purposes, and could be changed without previous notice